

# 2025 WATER QUALITY REPORT FOR ALLERTON WATER WORKS

This report contains important information regarding the water quality in our water system. The source of our water is surface water. All of the water is purchased. Purchased water comes from Rathbun Regional Water Assn (Rathbun). Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	31.00 (24 - 38)	03/31/2025	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	LRAA	30.00 (30 - 30)	09/30/2025	No	By-products of drinking water disinfection
Copper (ppm)	AL=1.3 (1.3)	90th	0.125 (0.0092 - 0.135)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90th	0.00 (ND - 3)	2023	No	Corrosion of household plumbing systems; erosion of natural deposits
<b>950 - DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.6 (2 - 3.4)	03/31/2025	No	Water additive used to control microbes

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

## DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

## GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or

potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Our water supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formulas, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact ALLERTON WATER WORKS at 641-344-8470. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead tap sampling data can be found in the Iowa Drinking Water Data Portal: <https://programs.iowadnr.gov/iowadrinkingwater>

Our water supply has completed a service line inventory. Please contact us for information regarding the inventory and how you can access the results.

**OTHER VIOLATIONS**

In September 2025 we failed to monitor for Nitrite (as N). Adverse health effects, if any, are not known. Monitoring procedures have been corrected to avoid future violations.

**SOURCE WATER ASSESSMENT INFORMATION**

This water supply obtains some or all of its water from another public water supply. It is a consecutive water supply, where an originating parent supply provides drinking water to one or more downstream supplies.

Original Supply ID	Original Supply Name
IA0400900	Rathbun Regional Water Assn (Rathbun)

**OTHER INFORMATION**

Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

**CONTACT INFORMATION**

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact ALLERTON WATER WORKS at 641-344-8470.

**PURCHASED WATER INFORMATION**

Our water system purchases water from the system(s) shown below. Their water quality is as follows:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
0400900 - RATHBUN REGIONAL WATER ASSN (RATHBUN)						
01 - EAST PLANT @ AFTER TREATMENT						
Fluoride (ppm)	4 (4)	SGL	0.74	01/13/2022	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.06	01/13/2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	28	01/17/2025	No	Erosion of natural deposits; Added to water during treatment process
Atrazine (ppb)	3 (3)	SGL	0.30	05/13/2025	No	Runoff from herbicide used on row crops
Dalapon (ppb)	200 (200)	SGL	0.30	04/06/2022	No	Runoff from herbicide used on rights of way
03 - WEST PLANT @ AFTER TREATMENT						
Fluoride (ppm)	4 (4)	SGL	0.68	01/13/2023	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.07	01/13/2023	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	29	01/17/2025	No	Erosion of natural deposits; Added to water during treatment process
Atrazine (ppb)	3 (3)	SGL	0.20	05/17/2023	No	Runoff from herbicide used on row crops
Turbidity (NTU)	N/A (N/A)	TT	Enter highest single measurement and the lowest monthly percentage of samples meeting turbidity limits here.			Soil runoff

# 2025 WATER QUALITY REPORT FOR RATHBUN REGIONAL WATER ASSN (RATHBUN)

This report contains important information regarding the water quality in our water system. The source of our water is surface water. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM] DB01	80 (N/A)	LRAA	41 (33 - 43)	04/30/2025	No	By-products of drinking water chlorination
Total Trihalomethanes (ppb) [TTHM] DB02	80 (N/A)	LRAA	40 (30 - 48)	04/30/2025	No	By-products of drinking water chlorination
Total Trihalomethanes (ppb) [TTHM] DB03	80 (N/A)	LRAA	39 (30 - 46)	04/30/2025	No	By-products of drinking water chlorination
Total Trihalomethanes (ppb) [TTHM] DB04	80 (N/A)	LRAA	43 (34 - 46)	04/30/2025	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5] DB01	60 (N/A)	LRAA	2 (15 - 21)	04/30/2025	No	By-products of drinking water disinfection
Total Haloacetic Acids (ppb) [HAA5] DB02	60 (N/A)	LRAA	20 (13 - 20)	04/30/2025	No	By-products of drinking water disinfection
Total Haloacetic Acids (ppb) [HAA5] DB03	60 (N/A)	LRAA	16 (12 - 19)	04/30/2025	No	By-products of drinking water disinfection
Total Haloacetic Acids (ppb) [HAA5] DB04	60 (N/A)	LRAA	19 (7 - 19)	04/30/2025	No	By-products of drinking water disinfection
Lead (ppb)	AL=15 (0)	90th	0.00 (ND - 5)	2023	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.26 (0.05 - 0.44)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
<b>950 - DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.95 (2.6 - 3.04)	06/30/2025	No	Water additive used to control microbes
<b>01 - EAST PLANT @ AFTER TREATMENT</b>						
Barium (ppm)	2 (2)	SGL	0.06	01/13/2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	(0.62 - 0.84)	2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	28	01/17/2025	No	Erosion of natural deposits; Added to water during treatment process
Atrazine (ppb)	3 (3)	SGL	0.30	05/13/2025	No	Runoff from herbicide used on row crops
Dalapon (ppb)	200 (200)	SGL	0.30	04/06/2022	No	Runoff from herbicide used on rights of way
Turbidity (NTU)	N/A (N/A)	TT	0.063 (100%)	2025	No	Soil runoff
Total Organic Carbon	30%	TT	(40.3 - 75.8)	01/2025	No	Naturally Present in the Environment

03 - WEST PLANT @ AFTER TREATMENT						
Barium (ppm)	2 (2)	SGL	0.07	01/13/2023	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	0.68	01/13/2023	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	29	01/17/2025	No	Erosion of natural deposits; Added to water during treatment process
Atrazine (ppb)	3 (3)	SGL	0.20	05/17/2023	No	Runoff from herbicide used on row crops
Turbidity (NTU)	N/A (N/A)	TT	0.089 (100%)	2025	No	Soil runoff
Total Organic Carbon	30%	TT	(40.0 – 59.5)	02/2025	No	Naturally Present in the Environment

## UCMR5

PFBA (ppb)	N/A (N/A)	SGL	0.0057 (0.0050-0.0057)	2024	No	Unregulated Contaminants Monitoring Rule, 5 <sup>th</sup> Edition
Yttrium (ppb)	N/A (N/A)	SGL	95.5 (95.3 - 95.5)	2024	No	Unregulated Contaminants Monitoring Rule, 5 <sup>th</sup> Edition
Lithium (ppb)	N/A (N/A)	SGL	2.1 (2.1 – 2.2)	2023	No	Unregulated Contaminants Monitoring Rule, 5 <sup>th</sup> Edition

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

## DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

## GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Our water supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formulas, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact RATHBUN REGIONAL WATER ASSN (RATHBUN) at 641-647-2416. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead tap sampling data can be found in the Iowa Drinking Water Data Portal: <https://programs.iowadnr.gov/iowadrinkingwater>

Our water supply has completed a service line inventory. Please contact us for information regarding the inventory and how you can access the results.

## SOURCE WATER ASSESSMENT INFORMATION

This water supply obtains water from one or more surface waters. Surface water sources are susceptible to sources of contamination within the drainage basin.

Surface Water Name	Susceptibility
Chariton River	high
Rathbun Lake	high

## OTHER INFORMATION

Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

## CONTACT INFORMATION

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact RATHBUN REGIONAL WATER ASSN (RATHBUN) at 641-647-2416.