

# 2025 WATER QUALITY REPORT

## LEON WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is surface water. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Copper (ppm)	AL=1.3 (1.3)	90 <sup>th</sup>	0.04 (ND - 0.07)	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90 <sup>th</sup>	3.00 (ND - 80) 1 sample(s) exceeded AL	2024	No	Corrosion of household plumbing systems; erosion of natural deposits
<b>950 - DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	2.15 (0.88 – 2.15)	10/31/2025	No	Water additive used to control microbes
Total Trihalomethanes (ppb) [TTHM] – DB01	80 (N/A)	LRAA	113 (67.2 – 77.8)	8/6/2025	No	By-products of drinking water chlorination
Total Trihalomethanes (ppb) [TTHM] – DB02	80 (N/A)	LRAA	108 (70.5 – 73.7)	8/6/2025	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5] – DB01	60 (N/A)	LRAA	87.5 (79.1 – 84.2)	8/6/2025	Yes	By-products of drinking water disinfection
Total Haloacetic Acids (ppb) [HAA5] – DB02	60 (N/A)	LRAA	94.2 (75.8 – 81.1)	11/5/2025	Yes	By-products of drinking water disinfection
Asbestos (MFL)	7	SGL	0.80	4/30/2019	No	Decay of asbestos cement in water mains; erosion of natural deposits
<b>01 - FRM LITTLE RIVER AFTR TRMNT</b>						
Arsenic (ppb)	10 (0)	SGL	2.0	7/6/2021	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production waste.
Fluoride (ppm)	4 (4)	SGL	0.8 (0.2 - 0.8)	12/8/2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	22.6	7/9/2025	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	0.1	1/29/2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Atrazine (ppb)	3 (3)	SGL	0.42	7/9/2025	No	Runoff from herbicide used on row crops
Picloram (ppb)	500 (500)	SGL	ND	5/6/2025	No	Herbicide runoff
Dalapon (ppb)	200 (200)	SGL	ND	6/26/2024	No	Runoff from herbicide used on rights of way
Turbidity (NTU)	N/A (N/A)	TT	0.276 100% of samples met the requirements	6/29/2025	No	Soil runoff
Total Organic Carbon (TOC) (% Removed)	N/A	TT	58.1 (37.9 – 58.1)	8/2025	No	Naturally present in the environment

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

### DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

- ppb -- parts per billion.
- ppm -- parts per million.
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- LRAA – Locational Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units
- MFL – Millions of Fibers per Liter

## GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LEON WATER SUPPLY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## ADDITIONAL HEALTH INFORMATION

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested and flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the Safe Drinking Water Hotline (800-426-4791).

## CONTAMINANT VIOLATIONS

Violation Type	Contaminant	Begin Date	End Date
Our water system violated a drinking water standard for Total Haloacetic Acids (HAA5). Some people who drink water containing haloacetic acids in excess of the MCL over many years have an increased risk of getting cancer.			
MCL (Chem-Rad), Average	Total Haloacetic Acids (HAA5)	1/01/2025	3/31/2025
MCL (Chem-Rad), Average	Total Haloacetic Acids (HAA5)	4/01/2025	6/30/2025
MCL (Chem-Rad), Average	Total Haloacetic Acids (HAA5)	7/01/2025	9/30/2025
MCL (Chem-Rad), Average	Total Haloacetic Acids (HAA5)	10/01/2025	12/31/2025

**SOURCE WATER ASSESSMENT INFORMATION**

This water supply obtains water from one or more surface waters. Surface water sources are susceptible to sources of contamination within the drainage basin.

Surface Water Name	Susceptibility
Little River Reservoir	High

**OTHER INFORMATION**

Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

**CONTACT INFORMATION**

For questions regarding this information, please contact LEON CITY HALL at 641/446-6221 during the following hours: 8:00 a.m. – 4:30 p.m. M-TH and 8:00 a.m. – 3:30 p.m. Fri.

Decisions regarding the water system are made at the city council meetings held on the 2<sup>nd</sup> Monday of the month at 6:00 p.m. at LEON CITY HALL and are open to the public.

Please note: This report will not be mailed to each customer.