



CCR Certification Form

For Systems with mailing waivers

SLOAN WATER SUPPLY

PWSID: 9780059

The community water system indicated above hereby confirms that the Consumer Confidence Report (CCR) has been distributed to customers (and appropriate notices of availability have been given) and that the information is correct and consistent with the compliance monitoring data previously submitted to IDNR by your certified laboratory.

System-specific details on requirements of CCR distribution to customer are outlined below.

• Systems electing to distribute the CCR by direct delivery.

This can be accomplished by mail, electronic delivery, or other form of direct delivery. Provide the date of distribution and delivery method in the space below. Refer to the following website for electronic delivery options: <https://www.epa.gov/ccr/how-water-utilities-can-electronically-delivery-their-ccr>. Provide URL if distributed electronically.

• Systems electing not to distribute the CCR by direct delivery must complete all of the following.

Systems serving between 501 and 10,000 persons must:

1. Publish the CCR in the local newspaper(s). Attach a copy of the notice. List newspaper and dates below: *Ryan Publishing - (Arapahoe) April 09, 2026*
2. Inform customers the CCR will not be mailed. List methods and date of notification below: *Posted in City Hall, on City Facebook, on City website call on April 22, 2026*
3. Develop procedures to make reports available upon request. Specify below: *Added where residents could find this report on the City Facebook post.*

Systems serving fewer than or equal to 500 persons must:

Inform customers the CCR is available upon request and will not be mailed. List methods used and date completed below:

Certified by: Name David Meyers
 Title Maintenance Supervisor
 Phone # 712-251-4080 Date of Delivery 4/30/26

Return to: ATTN: Meg Oneal
 Iowa DNR Water Supply Operations Section
 6200 Park Ave STE 200
 Des Moines, IA 50321

4-29-26

Grapevine

APARTMENTS FOR RENT

For rent in Onawa:
2 BR, 1 Ba. Apartments
Laundry on-site.

advance procedure for
have questions or
ict's Equity Coordinator,
st St., Whiting, IA.
jcsd.org

2025 WATER QUALITY REPORT FOR SLOAN WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	50.00 (50 - 50)	09/30/2025	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	LRAA	8.00 (8 - 8)	09/30/2025	No	By-products of drinking water disinfection
Copper (ppm)	AL=1.3 (1.3)	90th	0.116 (0.0227 - 0.144)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90th	6.63 (1 - 17) 1 sample(s) exceeded AL	2023	No	Corrosion of household plumbing systems; erosion of natural deposits
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	0.7 (0.39 - 1.05)	12/31/2025	No	Water additive used to control microbes
Fluoride (ppm)	4 (4)	RAA	0.50 (0.5 - 0.5)	03/31/2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
01 - WL 1&2 OR WL 3/TREATMENT PLANT TAP						
Barium (ppm)	2 (2)	SGL	0.117	01/19/2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	100 (100)	SGL	2.43	01/19/2022	No	Discharge from steel and pulp mills; Erosion of natural deposits
Arsenic (ppb)	10 (0)	SGL	1.49	01/19/2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Fluoride (ppm)	4 (4)	SGL	0.5	08/06/2024	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	42.5	03/12/2025	No	Erosion of natural deposits; Added to water during treatment process

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL)-- The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L -- picocuries per liter
- N/A -- Not applicable
- ND -- Not detected
- RAA -- Running Annual Average