

2025 WATER QUALITY REPORT FOR SUPERIOR WATER SYSTEM

This report contains important information regarding the water quality in our water system. The source of our water is surface water and groundwater. All of the water is purchased. Purchased water comes from Iowa Lakes Regional Water (Clay Plant), Central Water System, Estherville Water Treatment Plant and IOWA LAKES REGIONAL WATER - OSGOOD. Note: The system did not purchase any water from the Estherville Water Treatment Plant in 2025.

Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	ND	2025	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.02 (ND - 0.04)	2025	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	1.8 (1.66 - 1.89)	12/31/2025	No	Water additive used to control microbes

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. Our water supply is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formulas, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact SUPERIOR WATER SYSTEM at 712-858-4528. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Lead tap sampling data can be found in the Iowa Drinking Water Data Portal: <https://programs.iowadnr.gov/iowadrinkingwater>

Our water supply has completed a service line inventory. Please contact us for information regarding the inventory and how you can access the results.

SOURCE WATER ASSESSMENT INFORMATION

This water supply obtains some or all of its water from another public water supply. It is a consecutive water supply, where an originating parent supply provides drinking water to one or more downstream supplies.

Original Supply ID	Original Supply Name
IA2100701	Iowa Lakes Regional Water
IA3000099	Central Water System
IA3218024	Estherville Water Treatment Plant
IA3060001	Iowa Lakes Regional Water – Osgood

(Note: ILRW did not purchase water from Estherville in 2025)

CONTACT INFORMATION

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact SUPERIOR WATER SYSTEM at 712-858-4528.

PURCHASED WATER INFORMATION

Our water system purchases water from the system(s) shown below. Their water quality is as follows:

3000099 - CENTRAL WATER SYSTEM TREATMENT PLANT-02-FINAL EFFLUENT SAMPLE TAP						
CONTAMINANT	MCL- (MCLG)	Type	Compliance Value & (Range)	Date	Violation Yes/No	Source
Barium (ppm)	2 (2)	SGL	0.06	08/17/2023	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	1.10	09/12/2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Arsenic (ppb)	10 (0)	SGL	<0.001	08/17/2023	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Sodium (ppm)	N/A (N/A)	SGL	15	08/25/2025	No	Erosion of natural deposits; Added to water during treatment process
Nitrate (as N) (ppm)	10 (10)	SGL	<0.1	08/25/2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Atrazine (ppb)	3 (3)	SGL	0.10	04/10/2023	No	Runoff from herbicide used on row crops
Dalapon (ppb)	200 (200)	SGL	1.10	04/10/2023	No	Runoff from herbicide used on rights of way
Manganese (ppm)	HA 0.3 (ppm)	SGL	<0.02	11/10/2025	No	Naturally occurring element found in soil, water and air
Turbidity (NTU)	1 NTU in 2 Consecutive Readings	TT	0.259 99.99%	09/30/2025	No	Soil runoff. Turbidity is an indicator of treatment filter performance and is regulated as a treatment technique.

2100701 - IOWA LAKES REGIONAL WATER-01-WELLS 1, 4-11 – CLAY TREATMENT PLANT TAP						
CONTAMINANT	MCL- (MCLG)	Type	Compliance Value & (Range)	Date	Violation Yes/No	Source
Fluoride (ppm)	4 (4)	RAA	0.54 (0.48 - 0.61)	2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.0218	04/12/2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	4.75	04/16/2025	No	Erosion of natural deposits; Added to water during treatment process
Manganese (ppm)	HA 0.3 (ppm)	SGL	<0.01	10/27/2025	No	Naturally occurring element found in soil, water and air
Nitrate [as N] (ppm)	10 (10)	SGL	0.138	04/16/2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

3060001 - IOWA LAKES REGIONAL WATER – OSGOOD TREATMENT PLANT						
			Compliance	Date	Violation	Source
CONTAMINANT	MCL- (MCLG)	Type	Value & (Range)		Yes/No	
Manganese (ppm)	HA 0.3 (ppm)	SGL	<0.01	7/29/2025	No	Naturally occurring element found in soil, water and air.
Fluoride (ppm)	4 (4)	RAA	0.69 (0.59-0.77)	12/31/2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	6.95	07/29/2025	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	0.337	07/29/2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits