

2024 WATER QUALITY REPORT FOR BLAIRSTOWN WATER SUPPLY

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	0.00 (ND - 2)	2023	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.201 (ND - 0.221)	2023	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	3.1 (ND - 3.6)	03/31/2024	No	Water additive used to control microbes
Nitrite [as N] (ppm)	1 (1)	SGL	1.270 (ND - 1.270)	2024	Yes	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
02 - FINISHED WATER TAP, #1/#2						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	6.5	03/13/2023	No	Erosion of natural deposits
Combined Radium (pCi/L)	5 (0)	SGL	2.5	03/13/2023	No	Erosion of natural deposits
Fluoride (ppm)	4 (4)	SGL	1.7	04/07/2021	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.0021	04/07/2021	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Selenium (ppb)	50 (50)	SGL	1.30	04/07/2021	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
Sodium (ppm)	N/A (N/A)	SGL	374	03/20/2024	No	Erosion of natural deposits; Added to water during treatment process
Nitrite [as N] (ppm)	1 (1)	SGL	0.430 (0.120 - 0.430)	2024	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable