

2025 WATER QUALITY REPORT FOR TREYNOR WATER DEPARTMENT

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	10.00 (10 - 10)	09/30/2025	No	By-products of drinking water chlorination
Lead (ppb)	AL=15 (0)	90th	5.00 (ND - 9)	2024	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.9 (0.01 - 1.0)	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	1.6 (1.12 - 2.14)	12/31/2025	No	Water additive used to control microbes
Nitrite [as N] (ppm)	1 (1)	SGL	0.17 (ND - 0.17)	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
01 - WELL 5_6 AFTR TRTMT @ PLANT						
Gross Alpha, inc (pCi/L)	15 (0)	SGL	1.4	10/09/2024	No	Erosion of natural deposits
Fluoride (ppm)	4 (4)	RAA	0.22 (0.2 - 0.3)	12/31/2025	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.18	06/14/2022	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	54	06/18/2025	No	Erosion of natural deposits; Added to water during treatment process
Nitrite [as N] (ppm)	1 (1)	SGL	0.17	2025	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA -- Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.