

## Annual Drinking Water Quality Report

2014

# City of Lost Nation Water Supply

We are pleased to provide you with this year's Annual Quality Water Report. This report contains important information regarding the water quality in our water system. The source of our water is groundwater. Our water quality testing shows the following results:

CONTAMINANT	MCL-(MCLG)	Compliance		Date	Violation Yes/No	Source
		Type	Value & (Range)			
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	LRAA	5.00 (5-5)	9/30/2014	No	By-products of drinking water chlorination
Copper (ppm)	AL=1.3 (1.3)	90 <sup>th</sup>	0.146 (0.0395-0.152)	2014	No	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (ppb)	AL=15 (0)	90 <sup>th</sup>	6.0 (2-6)	2014	No	Corrosion of household plumbing systems erosion of natural deposits
<b>950 – DISTRIBUTION SYSTEM</b>						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	0.8 (ND-1.13)	12/31/2014	No	Water additive used to control microbes
<b>03 – SEP FROM WELL #2</b>						
Nitrate [as N] (ppm)	10 (10)	SGL	1.1(0.38-1.1)	2014	No	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>02 – SEP FROM WELL #1</b>						
Fluoride (ppm)	4 (4)	SGL	0.2	05/20/2013	No	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Barium (ppm)	2 (2)	SGL	0.347	05/20/2013	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Sodium (ppm)	N/A (N/A)	SGL	25.300	12/31/2013	No	Erosion of natural deposits added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	11 (9.4-11)	2014	Yes	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

### DEFINITIONS:

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) – The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb – parts per billion
- ppm – parts per million
- pCi/L – picocuries per liter
- N/A – not applicable
- ND – not detected

- RAA – running annual average
- LRAA – locational running annual average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – single sample result
- TCR – total coliform rule

**GENERAL INFORMATION:**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or potential health effects can be obtained by calling the Environmental Protection Agency’s Safe Drinking Water Hotline (800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LOST NATION WATER SUPPLY is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Save Drinking Water Hotline (800-426-4791) or at <http://www.epa.gov/safewater/lead>.

**CONTAMINANT VIOLATIONS:**

As you can see from the report, the City of Lost Nation Water Supply violated the drinking water standard for Nitrate (as N). Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome. This violation was corrected by taking Well #1 off line. It will be used only in case of emergency and you will be notified.

Violation Type	Contaminant	Begin date	End date
MCL (Chem-Rad), single sample	Nitrate (as N)	02/01/2014	02/28/2014
MCL (Chem-Rad), single sample	Nitrate (as N)	03/01/2014	03/31/2014

**SOURCE WATER ASSESSMENT INFORMATION:**

This water supply obtains its water from the dolomite of the Silurian aquifer. The Silurian aquifer was determined to be slightly susceptible to contamination because the characteristics of the aquifer and overlying materials provide moderate protection from contaminants at the land surface. The Silurian wells will be slightly susceptible to surface contaminants such as leaking underground storage tanks, contaminant spills, and excess fertilizer application. A detailed evaluation of your source water was completed by the Iowa Department of Natural Resources, and is available from the Water Operator at 563-678-2443.

**CONTACT INFORMATION:**

For questions regarding this information or how you can get involved in decisions regarding the water system, please contact LOST NATION WATER SUPPLY at 563-678-2443. You are also invited to attend our regularly scheduled City Council meetings on the first Monday of every month at 6:30pm at City Hall (410 Main Street).