

2017 WATER QUALITY REPORT FOR HOSPERS MUNICIPAL WATER DEPT

This report contains important information regarding the water quality in our water system. The source of our water is groundwater. All of the water is purchased. Purchased water comes from Rural Water System #1. Our water quality testing shows the following results:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)			
Lead (ppb)	AL=15 (0)	90th	1.60 (ND - 10)	2016	No	Corrosion of household plumbing systems; erosion of natural deposits
Copper (ppm)	AL=1.3 (1.3)	90th	0.53 (0.0203 - 0.588)	2016	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
950 - DISTRIBUTION SYSTEM						
Chlorine (ppm)	MRDL=4.0 (MRDLG=4.0)	RAA	1.7 (1.55 - 1.99)	12/31/2017	No	Water additive used to control microbes
Total Trihalomethanes (ppb) [TTHM]	80 (N/A)	SGL	62.70	10/25/2017	No	By-products of drinking water chlorination
Total Haloacetic Acids (ppb) [HAA5]	60 (N/A)	SGL	44.20	10/25/2017	No	By-products of drinking water disinfection

Note: Contaminants with dates indicate results from the most recent testing done in accordance with regulations.

DEFINITIONS

- Maximum Contaminant Level (MCL) – The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Contaminant Level Goal (MCLG) -- The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- ppb -- parts per billion.
- ppm -- parts per million.
- pCi/L – picocuries per liter
- N/A – Not applicable
- ND -- Not detected
- RAA – Running Annual Average
- Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.
- Action Level (AL) – The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- SGL – Single Sample Result
- RTCR – Revised Total Coliform Rule
- NTU – Nephelometric Turbidity Units

GENERAL INFORMATION

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water posed a health risk. More information about contaminants or

PURCHASED WATER INFORMATION

Our water system purchases water from the system(s) shown below. Their water quality is as follows:

CONTAMINANT	MCL - (MCLG)	Compliance		Date	Violation	Source
		Type	Value & (Range)		Yes/No	
8400722 - RURAL WATER SYSTEM #1						
01 - ALL ACTIVE S WELLS PLANT 2, LAB SINK						
Fluoride (ppm)	4 (4)	SGL	1.3	10/23/2017	No	Water additive which promotes strong teeth; Erosion of natural deposits; Discharge from fertilizer and aluminum factories
Sodium (ppm)	N/A (N/A)	SGL	26	10/23/2017	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	2.7	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
02 - ALL ACTIVE S WELLS PLANT 3, LAB SINK						
Sodium (ppm)	N/A (N/A)	SGL	44.4	10/14/2015	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	1.8	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
07 - ALL ACTIVE PL1 WELLS/PLT 1 HS HEADER						
Arsenic (ppb)	10 (0)	SGL	1.00	06/06/2016	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronic production wastes
Sodium (ppm)	N/A (N/A)	SGL	59	06/06/2016	No	Erosion of natural deposits; Added to water during treatment process
Nitrate [as N] (ppm)	10 (10)	SGL	6.51 (3.93 - 6.51)	2017	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits